
Installation Manual

Two-Post Lift 9,000lbs. Capacity




Consulte ANSI/ALI ALIS, Requisitos de Seguridad para Instalación y Servicio de Elevadores Automotrices antes de instalar el elevador.

OPERATING CONDITIONS

Lift is not intended for outdoor use and has an operating ambient temperature range of 41°-104°F (5°-40°C)

LP50029



1. Lift Location: Use architects plan when available to locate lift. Fig. 1a & Fig. 1b shows dimensions of a typical bay layout.

AWARNING DO NOT install this lift in a pit or depression due to fire or explosion risks.

POWER LINIT HEIGHT	72-1/2"
LIFTING HEIGHT W/ 5" EXTENSION	76-5/8" W/ 68" STROKE
MIN. LIFT HEIGHT	3-5/8"
MIN. LIFT HEIGHT W/ 1 3/4" ADAPTER	5-3/8"
MIN. LIFT HEIGHT W/ 5" ADAPTER	8 5/8"
OVERALL FLOOR WIDTH	131"
INSIDE COLUMNS 109"	
WIDTH BETWEEN CARRIAGES 107"	
HEIGHT OVERALL 142"	
MIN. FLOOR CEILING HEIGHT	144"
FLOOR TO OVERHEAD SWITCH	137-5/8"
DRIVE THRU CLEARANCE	90-1/4"
MINIMUM TO NEAREST OBSTRUCTION	132"
MINIMUM TO NEAREST OBSTRUCTION	156"
MINIMUM TO NEAREST OBSTRUCTION	72"
	MIN. LIFT HEIGHT W/ 1 3/4" ADAPTER MIN. LIFT HEIGHT W/ 5" ADAPTER OVERALL FLOOR WIDTH INSIDE COLUMNS WIDTH BETWEEN CARRIAGES HEIGHT OVERALL MIN. FLOOR CEILING HEIGHT FLOOR TO OVERHEAD SWITCH DRIVE THRU CLEARANCE MINIMUM TO NEAREST OBSTRUCTION MINIMUM TO NEAREST OBSTRUCTION

NOTES:

- 1.) ALL HEIGHT DIMENSIONS ARE WITHOUT LEVELING SHIMS.
- 2.) STANDARD HEIGHT LIFT SHOWN.
- 3.) " ANCHORING SYSTEM TESTED TO ANSI/ALI ALCTV 2006.

LIFT CAPACITY	9,000 LBS.
LIFTING SPEED (RISE TIME)	APPROXIMATELY 45 SECONDS UNLOADED
	APPROXIMATELY 51 SECONDS AT RATED CAPACITY
MOTOR RATING OPTIONS	SINGLE PHASE 208-240V 50-60Hz 18-23 AMPS
	3 PHASE 208-230/460V 50-60Hz 17/8.5-14/8 AMPS
WEIGHT	1500 LBS
MECHANICAL SAFETY LOCKS	AUTOMATIC ALL POSITIONS
MECHANICAL SAFETY RELEASE	MANUAL ALL BOTH COLUMNS
SWING ARM LOCKS	AUTOMATIC LOCKING ABOVE 2 1/2"
HYDRAULIC SAFETY SYSTEM	AUTOMATIC ALL POSITIONS
CYLINDERS	TWO, ONE PER COLUMN
CARRIAGE BEARINGS	EIGHT PER CARRIAGE, UHMW
SYNCHRONIZATION	EQUALIZATION CABLES
MIN. BAY SIZE	12' X 24' VERIFY WITH SITE PLAN & SERVICE VEHICLES

- **2. Power Unit Tee Cover Plate:** While power unit column is laying on the ground, install the cover plate using (2) M4x6 Lg. PHMS Fig. 2.
- **3. Hoses:** Clean adapters and hose. Inspect all threads for damage and hose ends to be sure they are crimped.

Flared Fittings Tightening Procedure


1. Screw the fittings together finger tight. Then, using the proper size wrench, rotate the fitting 2-1/2 hex flats.

IMPORTANT Flare seat MUST NOT rotate when tightening. Only the nut should turn.

- 2. Back the fitting off one full turn.
- 3. Again tighten the fittings finger tight; then using a wrench, rotate the fitting 2-1/2 hex flats. This will complete the tightening procedure and develop a pressure tight seal.


ACAUTION Overtightening will damage fitting resulting in fluid leakage.

Over tightening locknut may tear 0-ring or distort threads in pump manifold outlet.




4. Power Unit Tee: With the column still laying on the ground push the lift carriage as high as possible to install the power unit tee. Once carriage is rasied, install the power unit tee and hoses to the column Fig. 3


ACAUTION Overtightening will damage fitting resulting in fluid leakage.



5. Column Extensions: Install the column extensions using (2) 1/2"-13NC x 1 1/4" Carriage HHCS and Nylon Locknuts, Fig. 4.




6. Reinforcement Bar: Install the reinforcement bar to the column and column extension using (2) 1/2"-13NC x 1-1/4" HHCS, (4) 1/2" Flat Washer, and (2) 1/2"-13NC Nylon Locknut Fig. 5.




7. Latch Cable Guides: Install the latch cable conduit guide brackets to column extensions with (1) 1/4"-20NC x 1" HHCS and 1/4"-20NC Flanged Locknuts, HHCS should go through hole nearest the edge as shown, Fig. 6.

8. Lift Setting: Position columns in bay using dimensions shown in Fig. 1a & Fig. 1b. Place column with power unit mounting bracket on vehicle passenger side of lift. Both column base plate backs must be square on center line of lift. Notches are cut into each base plate to indicate center line of lift. Use appropriate equipment to raise carriage to first latch position. Be sure locking latch is securely engaged.



9. Cylinder Fitting/Flow Valve: Push the carriage to first lock and then install the flow valve and 90° elbow to the cylinder through the small opening on the bottom of the column. Fig 7.


ACAUTION Overtightening will damage fitting resulting in fluid leakage.





10a. Overhead Assembly: Fig. 9: Adjust overhead to appropriate dimension. Install (4) 3/8"-16NC x 3/4" HHCS & 3/8"-16NC Flanged Locknuts, do not tighten. Slide Switch Box over switch bar ensuring knock out holes face the power unit column. Use (2) 1/4"-20NC x 3/4" Ig. HHCS, 1/4" Flat Washer, and 1/4"-20NC Nuts to mount switch box to overhead, see Fig. 8.

10b. Continued Overhead Assembly:


For single phase lifts: Insert 1/4"-20NC x 2 3/4" HHCS through pivot hole in end of switch bar. Insert opposite end of bar through slot in switch mounting bracket. Then secure HHCS and Switch Bar to overhead as shown, Fig. 9, using (2) 3/4" spacers and 1/4"-20NC Locknut. Tighten Hex bolt leaving 1/16" gap between the spacer and the overhead assembly.







For three phase lifts: Remove Limit Switch cover, Fig. 10. Insert Actuator end of Switch Bar into slot located inside Limit Switch, Fig. 10. A small amount of silicone sealant on the lower part of the actuator will help hold it in place. Insert 1/4"-20NC x 2 3/4" HHCS through pivot hole in end of Switch Bar. Then secure HHCS and Switch Bar to overhead as shown, using (2) 3/4" spacers and 1/4"-20NC Locknut. Tighten Hex bolt leaving 1/16" gap between the spacer and the overhead assembly, Fig. 9. Replace limit switch cover.




Place Actuator Here.
A Small Amount Of Silicone Sealant
On The Lower Part Of The Actuator
Will Help Hold It In Place.

Actuator


Actuator

11. Overhead Installation: Install overhead assembly to Mounting Bracket with (2) M10-1.5 x 20mm HHCS, and (2) M10-1.5 Flanged Locknut Fig. 11. Tighten bolts at center of overhead assembly.



12. Power Unit: First install a star washer onto all of the (4) 5/16"-18NC x 1-1/2" HHCS. This is very important for grounding. Put the (4) 5/16"-18NC x 1-1/2" HHCS thru holes in power unit bracket, Fig. 12. Mount unit with motor up to column bracket and install (4) 5/16" star washers and 5/16" Nuts. Install and hand tighten fitting to pump until 0-ring is seated. Continue to tighten the locknut until the nut and washer bottom out against the pump manifold.


NOTE: You may still be able to rotate the fitting. This is acceptable unless there is seepage at the O-ring. If so, slightly tighten the locknut.




13. Adapter & Hose Installation (see Fig. 14)

- Connect the free end of the second shortest hose Pc. (2), from paragraph 3, to the power unit side cylinder Pc. (1). Run hose through channel inside column.
- 3. Run the free end of the longest hose Pc. (3), from paragraph 3, through hose clamps Pc.(9), and channel. Then connect it to the slave side cylinder.
- 4. Take the end of the remaining hose Pc. (4) out of the column and connect it to the fitting on the power unit Fig. 13.

NOTE: Overhead hose goes over top end of overhead assembly, Fig. 14 & Fig. 18a & Fig. 18b.








ITEM	QTY.	DESCRIPTION
1	2	Hydraulic Cylinder
2	1	Cylinder Hose
3	1	Slave Side Hose
4	1	Power Unit Hose
5	1	3/8" Branch Tee
6	2	Hose Clips
	2	M10-1.5 x 20mm HHCS
	2	M10-1.5 Flanged Locknuts
7	2	90° Fitting
8	2	Flow Control Valve

14. Equalizing Cables

- A) Refer to Fig. 16 for the general cable arrangement.
- B) First, run a cable end up through the small hole in the tie-off plate. Fig. 17.
- C) Push the cable up until the stud is out of the carriage top opening.
- D) Run a nylon insert locknut onto the cable stud so 1/2" (13mm) of the stud extends out of the locknut.
- E) Pull the cable back down, Fig. 17.
- F) Run cable around the lower sheave, then up and out of the top of the column.
- G) Run cable around overhead sheave and across and down to the opposite carriage. Install sheave cover, Fig. 15.
- H) Fasten the cable end to the carriage upper tie-off bracket, Fig. 17. Tighten the locknut enough to
- I) Adjust the tension of both cables during the final adjustments in Paragraph 24.









15. Locking Latch Cable

- A) Install latch cable sheave and retaining rings in upper slot of power unit column as shown, Fig. 19.
- B) Slip loop end of cable over end of shoulder screw on right side latch control plate, Fig. 19.
- C) Feed the other end of the cable through the latch cable sheave slot making sure that the cable is running under the bottom side of the latch cable sheave and inside the right column, Fig. 19.
- D) Attach latch cable conduit guide brackets to overhead as shown, Fig. 18a & Fig. 18b. Always use the holes on the approach side of the lift. HHCS should be in hole nearest the center of the overhead, Fig. 18b.
- E) Route cable up inside column and through the <u>latch cable</u> guide, Fig. 18a & Fig. 20.

IMPORTANT Using wire ties provided, tie off hydraulic hose snug to cylinders to keep hose away from equalizing cable, Fig. 14.

- F) Continue routing cable to the left column latch cable guide, Fig. 18a & Fig. 20, routing the cable through the left column latch cable guide, Fig. 18a.
- G) Bring the cable down inside the left column and feed the end of the cable through the lower latch cable sheave slot so that the cable is now back outside the column, Fig. 21.
- H) Route cable under the bottom side of the latch cable sheave, Fig. 21.
- At this point you MUST install the latch handle, jam nut, and right column latch cover Fig. 19 & Fig. 22. Install latch handle ball, Fig. 22.
- J) Insert cable in cable clamp along one side, loop around shoulder screw and back down, inserting cable along other side of cable clamp, Fig. 21. Place top back on clamp, barely tightening.
- K) Next, pull the control plate down, Fig. 20 & Fig. 21, to eliminate any clearance between the control plate slot and the latch dog pin, Fig. 20.
- L) Using Pliers, pull cable tight and secure the clamp close to the shoulder screw. Tighten clamp.





16. Concrete and Anchoring:


Drill (10) 3/4" dia. holes in concrete floor using holes in column base plate as a guide. See Fig. 24 for hole depth, hole spacing, and edge distance requirements.

ACAUTION DO NOT install on asphalt or other similar unstable surfaces. Columns are supported only by anchors in floor.

IMPORTANT Using the horse shoe shims provided, shim each column base until each column is plumb.


Recheck columns for plumb. Tighten anchor bolts to an installation torque of 110 ft-lbs. Shim thickness MUST NOT exceed 1/2" when using the 5-1/2" long anchors provided with the lift, Fig. 23. Adjust the column extensions plumb.

If anchors do not tighten to 110 ft-lbs. installation torque, replace concrete under each column base with a 4' \times 4' \times 6" thick 3000 PSI minimum concrete pad keyed under and flush with the top of existing floor. Let concrete cure before installing lifts and anchors.



NOTE: Use rectangular shims at inside edge of baseplate. Use constructions adhesive or silicon cement to hold shim in place. INSURE shims are held tightly between base plate and floor after torquing anchors.

NOTE: If more than 2 horse shoe shims are used at any of the column anchor bolts, pack non-shrink grout under the unsupported area of the column base. Insure shims are held tightly between the baseplate and floor after torquing anchors.



CONCRETE AND ANCHORING REQUIREMENTS				
STANDARD	ANSI/ALI ALCTV	IBC 2006,	2009, 2012	SEISMIC
Minimum Floor Thickness Anchor	4-1/4 INCHES Hilti Kwik Bolt III 3/4" x 5-1/2" Anchors supplied with the lift.*	5 INCHES Hilti HIT-HY 150 MAX-SD Adhe- sive; Hilti HIT-HY 150 MAX Adhesive; HILTI HIT-RE 500- SD Adhesive	6 INCHES Hilti Kwik Bolt III 3/4" x 7"	Varies by location consult with your structural engineer and manufacturer's representative.
Minimum Concrete Strength	3000 PSI	3000 PSI	3000 PSI	
Minimum Anchor Embed- ment	3-1/4 INCHES	3-1/2 INCHES	3-3/4 INCHES	
Minimum Distance to Concrete Edge, Crack, Expansion Joint, Aban- danoned Anchor Hole	4-1/2 INCHES	5-1/4 INCHES	3-1/4 INCHES	

*The supplied concrete fasteners meet the criteria of the American National Standard "Automotive Lifts - Safety Requirements for Construction, Testing, and Validation" ANSI/ALI ALCTV-2011, and the lift owner is responsible for all charges related to any additional anchoring requirements as specified by local codes.

Contact customer service for further information at: 800.640.5438

17. Electrical: Have a certified electrician run appropriate power supply to motor, Fig. 20 & 21. Size wire for 20 amp circuit. See Motor Operating Data Table.

Never operate the motor on line voltage less than 208V. Motor damage may occur.

IMPORTANT: Use separate circuit for each power unit. Protect each circuit with time delay fuse or circuit breaker. For single phase 208-230V, use 20 amp fuse. Three phase 208-240V, use 20 amp fuse. For three phase 400V and above, use 10 amp fuse. For three phase 380V use 16 amp fuse. For wiring see Fig. 20 & Fig. 21. All wiring must comply with NEC and all local electrical codes.


Note: 60Hz. single phase motor **CAN NOT** be run on 50Hz. line without a physical change in the motor.

NOTE: Assure cord used for connection between the overhead switch and power unit is of the type specified in:

UL201, Sections 10.1.1.3 & 10.1.1.4


(Example: SO, G, STO) Size for 25 amp circuit. See UL 201, Section 15 for proper wiring requirements for this connection.

Service From
Master Control Panel
(3 Wire) Into Junction
Box On Power Unit
Attach With Strain
Relief Provided



Single Phase Power Unit


MOTOR OPERATING DATA TABLE - SINGLE PHASE			
LINE VOLTAGE	RUNNING MOTOR VOLTAGE RANGE		
208-230V 50Hz.	197-253V		
208-230V 60Hz.	197-253V		




Note: 60Hz. Single phase motor CAN NOT be run on 50Hz. line without a physical change in the motor.



Three Phase Power Unit MOTOR OPERATING DATA - THREE PHASE LINE VOLTAGE RUNNING MOTOR VOLTAGE RANGE 208 - 230 Volts 60 HZ 197 - 253 Volts 460 Volts 60 HZ 414 - 506 Volts





NOTES:

- 1. Unit not suitable for use in unusual conditions. Contact VSG for moisture and dust environment duty unit.
- 2. Verify Coil Rating Matches Supply Voltage
- 3. Motor rotation is counter clockwisewhen viewed from top of motor.

18. Oil Filling & Bleeding: Use Dexron III ATF, or Hydraulic Fluid that meets ISO 32 specifications. Remove fill-breather cap, Fig. 12. Pour in (8) quarts of fluid. Start unit, raise lift about 2 ft. Open cylinder bleeders approximately 2 turns, Fig. 14.


Close bleeders when fluid streams. Torque values for the bleeders are 15 ft. lb. minimum and 20 ft lb. maximum. Fully lower lift. Add more fluid until it reaches the MIN_____ mark on the tank. Replace fill-breather cap.


ACAUTION If fill-breather cap is lost or broken, order replacement. Reservoir must be vented.


19. Overhead switch: Check overhead switch assembly to assure that switch bar is depressing switch plunger sufficiently to actuate the switch. The overhead switch is wired normally open, see Fig. 25a & Fig. 25b. Lift will not operate until weight of switch bar is depressing switch plunger. Verify that Power Unit stops working when switch bar is raised, and restarts when the bar is released.

20. Actuator:


- A) Screw gear shim onto the actuator pin all the way to the end of the threads, Fig. 26a.
- B) Insert actuator pin into bracket as shown in Fig.26b. Install spring and secure in place with 3 mm spring pin.
- C) Install restraint pawl, flat washer, and lock washer onto actuator pin. Install 10 mm nut but do not tighten, Fig. 26c.
- D) Install and tighten ball handle, Fig. 26d.








21. Arms & Restraints: Before installing arms, raise carriages to a convenient height. Grease swivel arm pins and holes with Lithium grease. Lift up on spring to allow gear on arm to slide in. Slide arm into yoke, Fig. 26. Install 1-3/4" diameter arm pin(s).




NOTE: To check operation of arm restraints, raise carriage 1" min. from full down position. Pull up on pin-ring and adjust arms to desired position. To engage restraint, let pin-ring down allowing gear teeth to mesh together. It may be necessary to rotate arm slightly to engage gear teeth. Tighten nut on actuator pin once restraint function is verified.




NOTE: Once arm is installed in yoke, pull up actuator pin and swing arm fully around, being sure that the Restraint Gear and Gear Block always stay aligned. If they do not stay aligned, remove restraint gear and install in the opposite position.

22. Exterior Adapters: Install adapter bracket to outside of each column using (2) 5/16"-18NC x 3/8" PHMS. Then, add adapters to the bracket as shown, Fig. 27.



25. Equalizer Cable Adjustment: Raise lift to check equalizer cable tension. Below carriage, grasp adjacent cables between thumb and forefinger, with about 15 lbs. effort you should just pull the cables together, Fig. 28. Adjust at upper tie-offs Fig. 17.



26. Latch Release Decal: Install latch release decal on cover above latch release handle, Fig. 29.

23. Latch Cable Adjustment:

- A) Check to make sure the latch will properly engage and disengage. Slowly release the latch handle.
 A 1/8" gap between the top of the latch dog and the column is allowable.
- B) When raising, listen to latches to be sure that both latch dogs fall into latch slots. If they do not, loosen clamp and adjust tension as necessary.
- C) Install left latch cover using 5/16-18NC x 3/8" lg PHMS.
- **24. Pressure Test:** Run lift to full rise and keep motor running for 5 seconds. Stop and check all hose connections. Tighten or reseal if required. Repeat air bleeding of cylinders.

